

Table G-9

**2005 - Bay Area Steam Units at Analytical Maximum; Hunters Point Shut Down; New 240 MW in San Francisco;
Transmission Increased to Serve SF Load and Reduce BARR without full New 480 MW**

PLANT/UNIT	TYPE	FUEL	NET CAPACITY (MW)	GENERATION (GWh)	CAPACITY FACTOR (percent)	EMISSIONS													
						NO _x			SO _x /H ₂ S			PM10			CO				
						Tons	#/MWh	#/MMBtu	Tons	#/MWh	#/MMBtu	Tons	#/MWh	#/MMBtu	Tons	#/MWh	#/MMBtu		
Hunters Point plant retired																			
Potrero	3	ST	NG	207	1148	63.3	70	0.12	0.012	6	0.01	0.001	44	0.08	0.007	477	0.83	0.082	
	4	CT	DF	52	45	9.9	48	2.12	0.164	29	1.29	0.100	3	0.15	0.012	4	0.18	0.014	
	5	CT	DF	52	43	9.5	46	2.12	0.164	28	1.29	0.100	3	0.15	0.012	4	0.18	0.014	
	6	CT	DF	52	38	8.4	41	2.13	0.165	25	1.29	0.100	3	0.15	0.012	3	0.18	0.014	
	Σ			363	1275	40.1	204	0.32	0.031	87	0.14	0.013	53	0.08	0.008	488	0.77	0.074	
Contra Costa	6	ST	NG	340	2114	71.0	124	0.12	0.012	10	0.01	0.001	77	0.07	0.008	843	0.80	0.082	
	7	ST	NG	340	2066	69.4	122	0.12	0.012	10	0.01	0.001	75	0.07	0.007	823	0.80	0.082	
	Σ			680	4179	70.2	246	0.12	0.012	20	0.01	0.001	152	0.07	0.008	1666	0.80	0.082	
Pittsburg	1	ST	NG	163	647	45.3	578	1.79	0.164	4	0.01	0.001	27	0.08	0.008	290	0.90	0.082	
	2	ST	NG	163	1023	71.7	68	0.13	0.012	6	0.01	0.001	42	0.08	0.007	456	0.89	0.082	
	#3 retired																		
	#4 retired																		
	5	ST	NG	325	1718	60.3	104	0.12	0.012	9	0.01	0.001	65	0.08	0.007	707	0.82	0.082	
	6	ST	NG	325	2167	76.1	134	0.12	0.012	11	0.01	0.001	83	0.08	0.007	907	0.84	0.082	
	7	ST	NG	682	4334	72.5	266	0.12	0.012	22	0.01	0.001	165	0.08	0.008	1800	0.83	0.082	
	Σ			1658	9890	68.1	1150	0.23	0.023	51	0.01	0.001	380	0.08	0.007	4160	0.84	0.082	
New 240 MW	CC	NG	240	1905	90.6	92	0.10	0.014	6	0.01	0.001	51	0.05	0.008	75	0.08	0.011		
Geysers	5	G	GS	39	284	83.0	1	0.00		72	0.50		1	0.01		0	0.00	1	0.01
	6	G	GS	39	285	83.3	1	0.00		59	0.41		1	0.01		0	0.00	1	0.01
	7	G	GS	37	279	86.0	0	0.00		74	0.53		1	0.01		0	0.00	1	0.01
	8	G	GS	37	278	85.8	0	0.00		58	0.42		1	0.01		0	0.00	1	0.01
	9	G	GS	32	210	74.9	1	0.01		36	0.34		1	0.01		0	0.00	1	0.01
	10	G	GS	32	208	74.2	1	0.01		49	0.47		1	0.01		0	0.00	1	0.01
	11	G	GS	56	463	94.5	0	0.00		133	0.57		1	0.01		0	0.00	2	0.01
	12	G	GS	39	291	85.2	1	0.01		73	0.50		1	0.01		0	0.00	1	0.01
	13	G	GS	69	573	94.8	0	0.00		27	0.09		2	0.01		0	0.00	2	0.01
	14	G	GS	61	473	88.5	0	0.00		24	0.10		1	0.01		0	0.00	2	0.01
	16	G	GS	69	574	94.9	0	0.00		4	0.02		2	0.01		0	0.00	2	0.01
	17	G	GS	47	366	88.8	0	0.00		10	0.06		1	0.01		0	0.00	1	0.01
	18	G	GS	62	482	88.7	1	0.00		33	0.14		1	0.01		0	0.00	2	0.01
	20	G	GS	46	350	86.9	1	0.00		19	0.11		1	0.01		0	0.00	1	0.01
	Σ			665	5115	87.8	7	0.00		672	0.26		15	0.01		2	0.00	21	0.01
Non-BAAQMD California Load-Related						265203	198172	1.49		99373	0.75		11966	0.09		47536	0.36	25163	0.19
Total Calif. Load-Related						282452	199864	1.42		99538	0.70		12603	0.09		53925	0.38	25877	0.18

UNIT TYPES: CT combustion turbine
 ST steam turbine
 G geothermal steam
 CC combined cycle

FUELS: NG natural gas w/ residual oil backup
 DF distillate fuel oil
 GS geothermal steam

NOTES: - All units assumed to use their primary fuels exclusively
 - Geothermal units dispatched economically per existing steam supply contracts
 - Geothermal units emit H₂S but basically no SO_x
 - Reflects latest 1998 AP42 updates
 - 115/230 kV transmission into SF assumed to be increased to about 800 MW